

## NOTICE TO BIDDERS

Faulkner County will be accepting sealed bids on Controls Replacement for the Detention Center.

Bid specifications and Submittal forms may be obtained from the Faulkner County Judge's Office. Bids will be accepted until 9:00 am on February 12, 2020 at which time they will be opened at the Faulkner County Judge's Office, located at 801 Locust Street Conway AR, 72034. Faulkner County reserves the right to accept or reject any or all bids placed and waive formalities.

Bids should be submitted in total including taxes, for the price to be paid by Faulkner County.

Direct questions and requests for clarifications related to this RFP to Sheriff Tim Ryals at 501-450-4914.

Bids may be mailed to:

Faulkner County Judge's Office  
Attn: Controls Replacement  
801 Locust Street  
Conway AR, 72034

BID INFORMATION AND BID SPECIFICATIONS

FOR

CONTRACTOR BIDDING PROJECT

THIS BID PACKET CONTAINS INFORMATION  
CONCERNING PROJECT FOR  
FAULKNER COUNTY, ARKANSAS  
COUNTY JUDGE JIM BAKER

Controls Replacement

January 21, 2020

Faulkner County, Arkansas

Controls Replacement

Date: January 21, 2020

Reference: Controls Replacement

Bid is to be addressed to:

Faulkner County Judge's Office  
Attn: Controls Replacement  
801 Locust Street  
Conway AR, 72034

**BIDS ARE DUE ON Wednesday, February 12, 2020 @ 9:00am**

Bids may be mailed or hand delivered to Judge Jim Baker, County Judge, Faulkner County, Arkansas. All bids must be turned in prior to the 9:00 AM deadline.

\*\*\*\*\*Faxed, Phone, or e-mail bids will not be accepted.

\*\*\*\*\*All bids must be in a sealed envelope and marked Attn: Controls Replacement

**Faulkner County Sheriff's Office Controls Replacement Requirements and Specifications**

- **Furnish and install two (2) New Control Stations for Tower Control at the Faulkner County Detention Center**
- **Furnish and install one (1) New Control Station for the Central Control Room at the Faulkner County Detention Center**
- **Furnish and install one (1) New Control Station for the Juvenile Control Room at the Faulkner County Detention Center**
- **Replace existing push buttons panels and control relays**
- **Install new UPS for each control panel**
- **New control system shall use Industrial PLC control and monitor (or similar to)**
- **System shall be via mouse control**
- **Doors shall be able to be controlled from either Tower or with each other.**
- **The system should be able to control and monitor a total of 65 doors (Tower) and 16 doors in Central Control and Juvenile**

**Provider must furnish and install the following:**

- 1) **Quantity Four (4) – 32" Color HDMI Monitors**
- 2) **Quantity Four (4)- C-More Industrial Solid-State PC (or similar)**
- 3) **Quantity Four (4)- APC SMT 1500 UPS (or similar)**
- 4) **Quantity Four (4) – Mirco PLC Controllers and I/O (or similar)**
- 5) **Quantity Seventy Six (76) – Door Relays**
- 6) **Quantity One (1) – 9 Conductor Cable for Door 304A**

Faulkner County, Arkansas

Controls Replacement

## BID SHEET

Total Bid Price including taxes: \_\_\_\_\_

Delivery Date: \_\_\_\_\_

Company Name: \_\_\_\_\_

Company Representative (Print name): \_\_\_\_\_

Company Representative (Signed Name): \_\_\_\_\_

Date: \_\_\_\_\_